

Environmental Services Analysis Report - Final

Invoice Number: 3384678	Collected Date: 19-Jul-2021 6:50 AM
Sample Location: 621 Main St	Received: 19-Jul-2021 11:42 AM
Collected by: Kelly Kish	Reported: 20-Jul-2021 11:11 AM
Station #: SK05NE0001	Water Source: Distributed
Permit: 2277	
Station Name: KIPLING DIST.SYSTEM	

Submitted By:	Invoice:
KIPLING TOWN OF	KIPLING TOWN OF
BOX 299	BOX 299
KIPLING, SK	KIPLING, SK
S0G 2S0	S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-2515 **Emailed results to:** kiptown@sasktel.net
kellykish@swwa.ca

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority	Total Fees (including GST)	23.00
	c/o Finance	Tax Summary	1.10
	2180 23rd Avenue	G.S.T. (reg # 89583 0180 RT001)	
	Regina, Saskatchewan	Amount Received: (No Payment Received)	0.00
	S4S 0A5		
Balance Due upon receipt of invoice.			
			Balance Owed \$23.00

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-787-6517
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 1.00 Total Chlorine: 1.08 Turbidity: .17

*580-290-100
UT (lab testing)*