

**Environmental Services Analysis Report - Final**

<b>Invoice Number:</b> 3432718	<b>Collected Date:</b> 01-May-2023 7:15 AM
<b>Sample Location:</b> Kipling Esso	<b>Received:</b> 01-May-2023 1:49 PM
<b>Collected by:</b> Kelly Kish	<b>Reported:</b> 02-May-2023 2:11 PM
<b>Station #:</b> SK05NE0001	<b>Water Source:</b> Distributed
<b>Submitted By:</b> Kipling Town of Box 299 Kipling, SK S0G 2S0	<b>Permit:</b> 2277 KIPLING DIST.SYSTEM
	<b>Invoice:</b> Kipling Town of Box 299 Kipling, SK S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

**Submitter Phone Number:** 306-736-2515      **Emailed results to:** kiptown@sasktel.net  
kellykish@swwa.ca

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	<b>Saskatchewan Health Authority</b>	<b>Total Fees (including GST)</b>	<b>23.00</b>
	<b>c/o Finance</b>	<b>Tax Summary</b>	<b>1.10</b>
	<b>2180 23rd Avenue</b>	G.S.T. (reg # 89583 0180 RT001)	
	<b>Regina, Saskatchewan</b>	<b>Amount Received: (No Payment Received)</b>	<b>0.00</b>
	<b>S4S 0A5</b>		
<b>Balance Due upon receipt of invoice.</b>			
			<b>Balance Owed \$23.00</b>

**Contact Us:**  
*Result Interpretation:* Please contact your EPO for advice or phone 306-535-4347  
*Billing Inquiries:* Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	.59	Total Chlorine:	.61	Turbidity:	.13
----------------	-----	-----------------	-----	------------	-----