

## Environmental Services Analysis Report - Final

|                                     |   |  |
|-------------------------------------|---|--|
| <b>Invoice Number:</b> 3501647      | <b>Collected Date:</b> 14-Apr-2025 11:50 AM |  |
| <b>Sample Location:</b> Water Plant | <b>Received:</b> 15-Apr-2025 2:16 PM        |  |
| <b>Collected by:</b> Kelly Kish     | <b>Reported:</b> 16-Apr-2025 2:07 PM        |  |
| <b>Station #:</b> SK05NE0001        | <b>Water Source:</b> Distributed            |  |
| <b>Permit:</b> 2277                 |   |  |
| KIPLING DIST.SYSTEM                 |   |  |

|                      |                 |
|----------------------|-----------------|
| <b>Submitted By:</b> | <b>Invoice:</b> |
| KIPLING TOWN OF      | KIPLING TOWN OF |
| BOX 299              | BOX 299         |
| KIPLING, SK          | KIPLING, SK     |
| S0G 2S0              | S0G 2S0         |

| Analysis       | Result        | Unit        | Sask Guideline | Test Comment | Fee   |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel  |               |             |                |              | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | <b>1</b>     |       |
| E. Coli        | No Detectable | orgs/100 mL | No orgs/100 mL | <b>2</b>     |       |

|   |   |
|---|---|
| <b>Submitter Phone Number:</b> 306-736-8805 | <b>Emailed results to:</b> b.ackerman@townofkipling.ca<br>kellykish1964@gmail.com |
|---|---|

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include  
Invoice Number  
with payment  
and remit to:

**Saskatchewan Health Authority  
c/o Accounts Receivable  
2180 23rd Avenue  
Regina, Saskatchewan  
S4S 0A5**

Total Fees (including GST) 23.00

Tax Summary 1.10  
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

|                     |                |
|---------------------|----------------|
| <b>Balance Owed</b> | <b>\$23.00</b> |
|---------------------|----------------|

**Contact Us:**

**Result Interpretation:** Please contact your EPO for advice or phone 1-866-727-5420

**Billing Inquiries:** Phone: 1-833-989-5353, Email: SHAAR@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

|                     |                      |                 |
|---------------------|----------------------|-----------------|
| Free Chlorine: 0.70 | Total Chlorine: 0.73 | Turbidity: 0.11 |
|---------------------|----------------------|-----------------|