

Environmental Services Analysis Report - Final

Invoice Number: 3397387	Collected Date: 04-Jan-2022 6:10 AM
Sample Location: Water Plant	Received: 04-Jan-2022 1:42 PM
Collected by: Kelly Kish	Reported: 05-Jan-2022 2:05 PM
Station #: SK05NE0001	Water Source: Distributed

Permit: 2277
KIPLING DIST.SYSTEM

Submitted By: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	Invoice: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-2515	Emailed results to: kiptown@sasktel.net kellykish@swwa.ca
---	---

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST) 23.00 Tax Summary 1.10 G.S.T. (reg # 89583 0180 RT001)
Balance Due upon receipt of invoice.		Amount Received: (No Payment Received) 0.00
		Balance Owed \$23.00

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-787-6517
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.74	Total Chlorine: 0.76	Turbidity: 0.11
---------------------	----------------------	-----------------