

## Environmental Services Analysis Report - Final

|                                     |  |
|-------------------------------------|--|
| <b>Invoice Number:</b> 3399274      | <b>Collected Date:</b> 31-Jan-2022 7:33 AM |
| <b>Sample Location:</b> Water Plant | <b>Received:</b> 31-Jan-2022 2:38 PM       |
| <b>Collected by:</b> Kelly Kish     | <b>Reported:</b> 01-Feb-2022 11:23 AM      |
| <b>Station #:</b> SK05NE0001        | <b>Water Source:</b> Distributed           |
| <b>Permit:</b> 2277                 |  |
| KIPLING DIST.SYSTEM                 |  |

|                      |                 |
|----------------------|-----------------|
| <b>Submitted By:</b> | <b>Invoice:</b> |
| KIPLING TOWN OF      | KIPLING TOWN OF |
| BOX 299              | BOX 299         |
| KIPLING, SK          | KIPLING, SK     |
| S0G 2S0              | S0G 2S0         |

| Analysis       | Result        | Unit        | Sask Guideline | Test Comment | Fee   |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel  |               |             |                |              | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | 1            |       |
| E. Coli        | No Detectable | orgs/100 mL | No orgs/100 mL | 2            |       |

|   |   |
|---|---|
| <b>Submitter Phone Number:</b> 306-736-2515 | <b>Emailed results to:</b> kiptown@sasktel.net<br>kellykish@swwa.ca |
|---|---|

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

|  |  |  |
|--|--|--|
| Please include Invoice Number with payment and remit to: | <b>Saskatchewan Health Authority</b><br><b>c/o Finance</b><br><b>2180 23rd Avenue</b><br><b>Regina, Saskatchewan</b><br><b>S4S 0A5</b> | <b>Total Fees (including GST)</b> 23.00<br><br><b>Tax Summary</b> 1.10<br>G.S.T. (reg # 89583 0180 RT001)<br><br>Amount Received: (No Payment Received) 0.00 |
| <b>Balance Due upon receipt of invoice.</b>              |  | <b>Balance Owed \$23.00</b>  |

**Contact Us:**

*Result Interpretation:* Please contact your EPO for advice or phone 306-787-6517  
*Billing Inquiries:* Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

|                    |                     |                |
|--------------------|---------------------|----------------|
| Free Chlorine: .75 | Total Chlorine: .83 | Turbidity: .09 |
|--------------------|---------------------|----------------|