



**Invoice Number:** 3393662  
**Sample Location:** Water Plant  
**Collected by:** Kelly Kish  
**Station #:** SK05NE0001  
**Permit:** 2277  
 KIPLING DIST.SYSTEM

**Collected Date:** 08-Nov-2021 7:10 AM  
**Received:** 08-Nov-2021 12:21 PM  
**Reported:** 09-Nov-2021 2:16 PM  
**Water Source:** Distributed

**Submitted By:**  
 KIPLING TOWN OF  
 BOX 299  
 KIPLING, SK  
 S0G 2S0

**Invoice:**  
 KIPLING TOWN OF  
 BOX 299  
 KIPLING, SK  
 S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

**Submitter Phone Number:** 306-736-2515

**Emailed results to:** kiptown@sasktel.net  
 kellykish@swwa.ca

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:

**Saskatchewan Health Authority  
 c/o Finance  
 2180 23rd Avenue  
 Regina, Saskatchewan  
 S4S 0A5**

Total Fees (including GST) 23.00

Tax Summary 1.10  
 G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

<b>Balance Owed</b>	<b>\$23.00</b>
---------------------	----------------

**Contact Us:**

**Result Interpretation:** Please contact your EPO for advice or phone 306-787-6517  
**Billing Inquiries:** Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .85      Total Chlorine: .88      Turbidity: .24