

## Environmental Services Analysis Report - Final

|                                     |  |
|-------------------------------------|--|
| <b>Invoice Number:</b> 3449031      | <b>Collected Date:</b> 27-Nov-2023 7:01 AM |
| <b>Sample Location:</b> 621 Main St | <b>Received:</b> 27-Nov-2023 12:04 PM      |
| <b>Collected by:</b> Kelly K.       | <b>Reported:</b> 28-Nov-2023 10:25 AM      |
| <b>Station #:</b> SK05NE0001        | <b>Water Source:</b> Distributed           |

**Permit: 2277**  
KIPLING DIST.SYSTEM

|                      |                 |
|----------------------|-----------------|
| <b>Submitted By:</b> | <b>Invoice:</b> |
| KIPLING TOWN OF      | KIPLING TOWN OF |
| BOX 299              | BOX 299         |
| KIPLING, SK          | KIPLING, SK     |
| S0G 2S0              | S0G 2S0         |

| Analysis       | Result        | Unit        | Sask Guideline | Test Comment | Fee   |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel  |               |             |                |              | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | 1            |       |
| E. Coli        | No Detectable | orgs/100 mL | No orgs/100 mL | 2            |       |

|   |   |
|---|---|
| <b>Submitter Phone Number:</b> 306-736-2515 | <b>Emailed results to:</b> kiptown@sasktel.net<br>kellykish@swwa.ca |
|---|---|

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

|  |   |
|--|---|
| Please include Invoice Number with payment and remit to:<br><br><b>Saskatchewan Health Authority</b><br><b>c/o Finance</b><br><b>2180 23rd Avenue</b><br><b>Regina, Saskatchewan</b><br><b>S4S 0A5</b> | Total Fees (including GST) <span style="float: right;">23.00</span><br><br>Tax Summary <span style="float: right;">1.10</span><br>G.S.T. (reg # 89583 0180 RT001) |
|--|---|

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

|                     |                |
|---------------------|----------------|
| <b>Balance Owed</b> | <b>\$23.00</b> |
|---------------------|----------------|

**Contact Us:**

*Result Interpretation:* Please contact your EPO for advice or phone 306-535-4347  
*Billing Inquiries:* Phone: (306) 766-5832, Email: corpFinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

|                     |                      |                 |
|---------------------|----------------------|-----------------|
| Free Chlorine: 0.49 | Total Chlorine: 0.51 | Turbidity: 0.13 |
|---------------------|----------------------|-----------------|