

## Environmental Services Analysis Report - Final

<b>Invoice Number:</b> 3504569	<b>Collected Date:</b> 20-May-2025 11:58 AM
<b>Sample Location:</b> Esso	<b>Received:</b> 21-May-2025 3:02 PM
<b>Collected by:</b> Kelly Kish	<b>Reported:</b> 22-May-2025 10:36 AM
<b>Station #:</b> SK05NE0001	<b>Water Source:</b> Distributed
<b>Permit:</b> 2277 KIPLING DIST.SYSTEM	

<b>Submitted By:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	<b>Invoice:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	<b>1</b>	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	<b>2</b>	

<b>Submitter Phone Number:</b> 306-736-8805	<b>Emailed results to:</b> b.ackerman@townofkipling.ca kellykish1964@gmail.com
---	---

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include  
Invoice Number  
with payment  
and remit to:

**Saskatchewan Health Authority  
c/o Accounts Receivable  
2180 23rd Avenue  
Regina, Saskatchewan  
S4S 0A5**

Total Fees (including GST) 23.00

Tax Summary 1.10  
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

**Balance Owed \$23.00**
**Contact Us:**

**Result Interpretation:** Please contact your EPO for advice or phone 1-866-727-5420

**Billing Inquiries:** Phone: 1-833-989-5353, Email: SHAAR@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .73	Total Chlorine: .75	Turbidity: .13
--------------------	---------------------	----------------