

## Environmental Services Analysis Report - Final

<b>Invoice Number:</b> 3461717	<b>Collected Date:</b> 05-Feb-2024 6:55 AM
<b>Sample Location:</b> 621 Main St	<b>Received:</b> 05-Feb-2024 11:59 AM
<b>Collected by:</b> Kelly Kish	<b>Reported:</b> 06-Feb-2024 10:24 AM
<b>Station #:</b> SK05NE0001	<b>Water Source:</b> Distributed

**Permit: 2277**  
KIPLING DIST.SYSTEM

<b>Submitted By:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	<b>Invoice:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

<b>Submitter Phone Number:</b> 306-736-8805	<b>Emailed results to:</b> kiptown@sasktel.net kellykish1964@gmail.com
---	---

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:

**Saskatchewan Health Authority  
c/o Finance  
2180 23rd Avenue  
Regina, Saskatchewan  
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

<b>Balance Owed</b>	<b>\$23.00</b>
---------------------	----------------

**Contact Us:**

*Result Interpretation:* Please contact your EPO for advice or phone 306-535-4347  
*Billing Inquiries:* Phone: (306) 766-5832, Email: corpFinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	0.50	Total Chlorine:	0.52	Turbidity:	0.14
----------------	------	-----------------	------	------------	------