

Environmental Services Analysis Report - Final

Invoice Number: 3477306	Collected Date: 21-May-2024 5:35 AM
Sample Location: Water Plant	Received: 21-May-2024 2:15 PM
Collected by: Kelly Kish	Reported: 22-May-2024 2:26 PM
Station #: SK05NE0001	Water Source: Distributed
Permit: 2277 KIPLING DIST.SYSTEM	

Submitted By: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	Invoice: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-8805	Emailed results to: kiptown@sasktel.net kellykish1964@gmail.com
---	---

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Accounts Receivable Department SHA - Financial Services 1920 College Avenue, 4th Floor W Regina, Saskatchewan S4P 0T1	Total Fees (including GST) 23.00 Tax Summary 1.10 G.S.T. (reg # 89583 0180 RT001)
		Amount Received: (No Payment Received) 0.00
Balance Due upon receipt of invoice.		Balance Owed \$23.00

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: (306) 766-5832, Email: corpFinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .79	Total Chlorine: .80	Turbidity: .11
--------------------	---------------------	----------------