

## Roy Romanow Provincial Laboratory **Environmental Services**

Permit: 2277

KIPLING DIST.SYSTEM

5 Research Drive Regina, Saskatchewan S4S 0A4

(306) 787-7138 / (306) 787-3140

## **Environmental Services Analysis Report - Final**

**Invoice Number:** 

3483121

Sample Location:

621 Main St

Collected by: Station #:

Kelly Kish

SK05NE0001

Collected Date:

29-Jul-2024 7:30 AM

Received:

30-Jul-2024 3:04 PM

Reported:

31-Jul-2024 2:23 PM

Water Source:

Distributed

Submitted By:

KIPLING TOWN OF

**BOX 299** KIPLING, SK S0G 2S0

Invoice:

KIPLING TOWN OF

**BOX 299** KIPLING, SK S0G 2S0

Analysis		lest			
	Result	Unit	Sask Guideline	Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

**Submitter Phone Number:** 

306-736-8805

Emailed results to:

kiptown@sasktel.net

kellykish1964@gmail.com

## Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water

2. See above for comment

Please include Invoice Number with payment and remit to:

**Accounts Receivable Department** 

SHA - Financial Services

1920 College Avenue, 4th Floor W

Regina, Saskatchewan

S4P 0T1

Total Fees (including GST)

Tax Summary

G.S.T. (reg # 89583 0180 RT001)

1.10

23.00

Amount Received: (No Payment Received)

0.00

Balance Due upon receipt of invoice.

**Balance Owed** \$23.00

## Contact Us:

Result Interpretation:

Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries:

Phone: (306) 766-5832, Email: corpFinance@rghealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:

.55

Total Chlorine:

.56

Turbidity:

.14