

Environmental Services Analysis Report - Final

| | | | |
|-------------------------|---------------------|------------------------|---------------------|
| Invoice Number: | 3385259 | Collected Date: | 26-Jul-2021 7:00 AM |
| Sample Location: | Water Plant | Received: | 26-Jul-2021 1:41 PM |
| Collected by: | Kelly Kish | Reported: | 27-Jul-2021 2:20 PM |
| Station #: | SK05NE0001 | Water Source: | Distributed |
| | Permit: 2277 | | |
| | KIPLING DIST.SYSTEM | | |

| | |
|----------------------|-----------------|
| Submitted By: | Invoice: |
| KIPLING TOWN OF | KIPLING TOWN OF |
| BOX 299 | BOX 299 |
| KIPLING, SK | KIPLING, SK |
| S0G 2S0 | S0G 2S0 |

| Analysis | Result | Unit | Sask Guideline | Test Comment | Fee |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel | | | | | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | 1 | |
| E. Coli | No Detectable | orgs/100 mL | No orgs/100 mL | 2 | |

| | | | |
|--------------------------------|--------------|----------------------------|--|
| Submitter Phone Number: | 306-736-2515 | Emailed results to: | kiptown@sasktel.net kellykish@swwa.ca |
|--------------------------------|--------------|----------------------------|--|

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

| | | |
|--|--|---|
| Please include Invoice Number with payment and remit to: | Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5 | Total Fees (including GST) 23.00 Tax Summary 1.10 G.S.T. (reg # 89583 0180 RT001) Amount Received: (No Payment Received) 0.00 |
| Balance Due upon receipt of invoice. | | Balance Owed \$23.00 |

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-787-6517
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

| | | |
|--------------------|---------------------|----------------|
| Free Chlorine: .89 | Total Chlorine: .97 | Turbidity: .14 |
|--------------------|---------------------|----------------|