

Environmental Services Analysis Report - Final

Invoice Number: 3435368
Sample Location: 621 Main St
Collected by: Kelly Kish
Station #: SK05NE0001
Permit: 2277
 KIPLING DIST.SYSTEM
Collected Date: 05-Jun-2023 7:09 AM
Received: 05-Jun-2023 1:32 PM
Reported: 06-Jun-2023 2:20 PM
Water Source: Distributed

Submitted By:
 KIPLING TOWN OF
 BOX 299
 KIPLING, SK
 S0G 2S0
Invoice:
 KIPLING TOWN OF
 BOX 299
 KIPLING, SK
 S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-2515
Emailed results to: kiptown@sasktel.net
 kellykish@swwa.ca

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .62 Total Chlorine: .14 Turbidity: 6.3