

## Environmental Services Analysis Report - Final

|                                          |                                            |  |
|------------------------------------------|--------------------------------------------|--|
| <b>Invoice Number:</b> 3408681           | <b>Collected Date:</b> 06-Jun-2022 7:45 AM |  |
| <b>Sample Location:</b> Water Plant      | <b>Received:</b> 06-Jun-2022 12:26 PM      |  |
| <b>Collected by:</b> Kelly Kish          | <b>Reported:</b> 07-Jun-2022 2:26 PM       |  |
| <b>Station #:</b> SK05NE0001             | <b>Water Source:</b> Distributed           |  |
| <b>Permit:</b> 2277                      |                                            |  |
| <b>Station Name:</b> KIPLING DIST.SYSTEM |                                            |  |

|                      |                 |
|----------------------|-----------------|
| <b>Submitted By:</b> | <b>Invoice:</b> |
| KIPLING TOWN OF      | KIPLING TOWN OF |
| BOX 299              | BOX 299         |
| KIPLING, SK          | KIPLING, SK     |
| S0G 2S0              | S0G 2S0         |

| Analysis       | Result        | Unit        | Sask Guideline | Test Comment | Fee   |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel  |               |             |                |              | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | <b>1</b>     |       |
| E. Coli        | No Detectable | orgs/100 mL | No orgs/100 mL | <b>2</b>     |       |

|                                             |                                                                     |
|---------------------------------------------|---------------------------------------------------------------------|
| <b>Submitter Phone Number:</b> 306-736-2515 | <b>Emailed results to:</b> kiptown@sasktel.net<br>kellykish@swwa.ca |
|---------------------------------------------|---------------------------------------------------------------------|

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include  
Invoice Number  
with payment  
and remit to:

**Saskatchewan Health Authority  
c/o Finance  
2180 23rd Avenue  
Regina, Saskatchewan  
S4S 0A5**

Total Fees (including GST) 23.00

Tax Summary 1.10  
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

|                     |                |
|---------------------|----------------|
| <b>Balance Owed</b> | <b>\$23.00</b> |
|---------------------|----------------|

**Contact Us:**

**Result Interpretation:** Please contact your EPO for advice or phone 306-535-4347  
**Billing Inquiries:** Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

|                    |                     |                |
|--------------------|---------------------|----------------|
| Free Chlorine: .51 | Total Chlorine: .59 | Turbidity: .12 |
|--------------------|---------------------|----------------|