

## Environmental Services Analysis Report - Final

|                                     |  |
|-------------------------------------|--|
| <b>Invoice Number:</b> 3494382      | <b>Collected Date:</b> 30-Dec-2024 8:01 AM |
| <b>Sample Location:</b> Water Plant | <b>Received:</b> 30-Dec-2024 11:25 AM      |
| <b>Collected by:</b> Kelly Kish     | <b>Reported:</b> 31-Dec-2024 10:21 AM      |
| <b>Station #:</b> SK05NE0001        | <b>Water Source:</b> Distributed           |
| <b>Permit:</b> 2277                 |  |
| KIPLING DIST.SYSTEM                 |  |

|                      |                 |
|----------------------|-----------------|
| <b>Submitted By:</b> | <b>Invoice:</b> |
| KIPLING TOWN OF      | KIPLING TOWN OF |
| BOX 299              | BOX 299         |
| KIPLING, SK          | KIPLING, SK     |
| S0G 2S0              | S0G 2S0         |

| Analysis       | Result        | Unit        | Sask Guideline | Test Comment | Fee   |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel  |               |             |                |              | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | 1            |       |
| E. Coli        | No Detectable | orgs/100 mL | No orgs/100 mL | 2            |       |

|   |   |
|---|---|
| <b>Submitter Phone Number:</b> 306-736-8805 | <b>Emailed results to:</b> kiptown@sasktel.net<br>kellykish1964@gmail.com |
|---|---|

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

|  |  |   |
|--|--|---|
| Please include Invoice Number with payment and remit to: | <b>Accounts Receivable Department<br/>SHA - Financial Services<br/>1920 College Avenue, 4th Floor W<br/>Regina, Saskatchewan<br/>S4P 0T1</b> | Total Fees (including GST) <span style="float: right;">23.00</span><br><br>Tax Summary <span style="float: right;">1.10</span><br>G.S.T. (reg # 89583 0180 RT001) |
|  |  | Amount Received: (No Payment Received) <span style="float: right;">0.00</span>  |
| Balance Due upon receipt of invoice.                     |  | <b>Balance Owed <span style="float: right;">\$23.00</span></b>  |

**Contact Us:**

*Result Interpretation:* Please contact your EPO for advice or phone 1-866-727-5420  
*Billing Inquiries:* Phone: 1-833-989-5353 or (306) 766-2304, Email: corpFinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

|                    |                     |                |
|--------------------|---------------------|----------------|
| Free Chlorine: .63 | Total Chlorine: .65 | Turbidity: .11 |
|--------------------|---------------------|----------------|