

Environmental Services Analysis Report - Final

| | |
|-------------------------------------|--|
| Invoice Number: 3374113 | Collected Date: 08-Mar-2021 7:10 AM |
| Sample Location: Water Plant | Received: 08-Mar-2021 1:06 PM |
| Collected by: Kelly Kish | Reported: 09-Mar-2021 2:13 PM |
| Station #: SK05NE0001 | Water Source: Distributed |
| Permit: 2277 | |
| KIPLING DIST.SYSTEM | |

| | |
|----------------------|-----------------|
| Submitted By: | Invoice: |
| KIPLING TOWN OF | KIPLING TOWN OF |
| BOX 299 | BOX 299 |
| KIPLING, SK | KIPLING, SK |
| S0G 2S0 | S0G 2S0 |

| Analysis | Result | Unit | Sask Guideline | Test Comment | Fee |
|----------------|---------------|-------------|----------------|--------------|-------|
| Regular Panel | | | | | 23.00 |
| Total Coliform | No Detectable | orgs/100 mL | No orgs/100 mL | 1 | |
| E. Coli | No Detectable | orgs/100 mL | No orgs/100 mL | 2 | |

| | |
|---|--|
| Submitter Phone Number: 306-736-2515 | Emailed results to: kiptown@sasktel.net glokel@sasktel.net |
|---|--|

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

 Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

| | |
|--|-------|
| Total Fees (including GST) | 23.00 |
| Tax Summary | 1.10 |
| G.S.T. (reg # 89583 0180 RT001) | |
| Amount Received: (No Payment Received) | 0.00 |

Balance Due upon receipt of invoice.

| | |
|---------------------|----------------|
| Balance Owed | \$23.00 |
|---------------------|----------------|

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-787-6517
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

| | | |
|---------------------|----------------------|----------------|
| Free Chlorine: 1.18 | Total Chlorine: 1.26 | Turbidity: .10 |
|---------------------|----------------------|----------------|