

Environmental Services Analysis Report - Final

Invoice Number: 3497275	Collected Date: 10-Feb-2025 11:33 AM
Sample Location: Esso	Received: 11-Feb-2025 3:46 PM
Collected by: Kelly Kish	Reported: 12-Feb-2025 2:13 PM
Station #: SK05NE0001	Water Source: Distributed
Permit: 2277 KIPLING DIST.SYSTEM	

Submitted By: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	Invoice: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-8805	Emailed results to: kiptown@sasktel.net kellykish1964@gmail.com
---	---

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to: Accounts Receivable Department SHA - Financial Services 1920 College Avenue, 4th Floor W Regina, Saskatchewan S4P 0T1	<table border="0" style="width: 100%;"> <tr> <td style="width: 80%;">Total Fees (including GST)</td> <td style="text-align: right;">23.00</td> </tr> <tr> <td>Tax Summary G.S.T. (reg # 89583 0180 RT001)</td> <td style="text-align: right;">1.10</td> </tr> <tr> <td>Amount Received: (No Payment Received)</td> <td style="text-align: right;">0.00</td> </tr> <tr> <td style="border: 1px solid black; text-align: right;">Balance Owed</td> <td style="border: 1px solid black; text-align: right;">\$23.00</td> </tr> </table>	Total Fees (including GST)	23.00	Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10	Amount Received: (No Payment Received)	0.00	Balance Owed	\$23.00
Total Fees (including GST)	23.00								
Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10								
Amount Received: (No Payment Received)	0.00								
Balance Owed	\$23.00								

Balance Due upon receipt of invoice.

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 1-866-727-5420
Billing Inquiries: Phone: 1-833-989-5353 or (306) 766-2304, Email: corpFinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.71	Total Chlorine: 0.73	Turbidity: 0.11
---------------------	----------------------	-----------------