

**Environmental Services Analysis Report - Final**

**Invoice Number:** 3434294 **Collected Date:** 23-May-2023 7:15 AM  
**Sample Location:** 621 Main St **Received:** 23-May-2023 1:10 PM  
**Collected by:** Kelly Kish **Permit:** 2277 **Reported:** 24-May-2023 2:20 PM  
**Station #:** SK05NE0001 **Water Source:** Distributed  
**Submitted By:** KIPLING DIST.SYSTEM

Submitted By:  
KIPLING TOWN OF  
BOX 299  
KIPLING, SK  
S0G 2S0

Invoice:  
KIPLING TOWN OF  
BOX 299  
KIPLING, SK  
S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

**Submitter Phone Number:** 306-736-2515 **Emailed results to:** kiptown@sasktel.net  
kellykish@swwa.ca

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:  
**Saskatchewan Health Authority  
c/o Finance  
2180 23rd Avenue  
Regina, Saskatchewan  
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

<b>Balance Owed</b>	<b>\$23.00</b>
---------------------	----------------

**Contact Us:**

**Result Interpretation:** Please contact your EPO for advice or phone 306-535-4347  
**Billing Inquiries:** Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .63 Total Chlorine: .67 Turbidity: .14