

Roy Romanow Provincial Laboratory Environmental Services

5 Research Drive Regina, Saskatchewan S4S 0A4

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number:

3501150

Sample Location: Collected by:

811 Main St

Kelly Kish SK05NE0001 Access and an access of the control of the control

KIPLING DIST.SYSTEM

Permit: 2277

Collected Date:

07-Apr-2025 11:33 AM

Received:

08-Apr-2025 12:47 PM 09-Apr-2025 2:18 PM

Reported: Water Source:

Distributed

Submitted By:

Station #:

KIPLING TOWN OF

BOX 299 KIPLING, SK S0G 2S0 Invoice:

KIPLING TOWN OF

BOX 299 KIPLING, SK S0G 2S0

Test

Analysis			iest		
	Result	Unit	Sask Guideline	Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number:

306-736-8805

Emailed results to:

b.ackerman@townofkipling.ca

kellykish1964@gmail.com

Comments:

- 1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
- 2. See above for comment

Please include Invoice Number with payment and remit to:

Accounts Receivable Department

SHA - Financial Services

1920 College Avenue, 4th Floor W

Regina, Saskatchewan

S4P 0T1

Total Fees (including GST)

23.00

Tax Summary

G.S.T. (reg # 89583 0180 RT001)

1.10

Amount Received: (No Payment Received)

0.00

Balance Due upon receipt of invoice.

Balance Owed \$23.00

Contact Us:

Result Interpretation:

Please contact your EPO for advice or phone 1-866-727-5420

Billing Inquiries:

Phone: 1-833-989-5353 or (306) 766-2304, Email: corpFinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:

.69

Total Chlorine:

.72

Turbidity:

.11