

Environmental Services Analysis Report - Final

Invoice Number: 3398778	Collected Date: 24-Jan-2022 7:00 AM
Sample Location: 401 2nd St	Received: 24-Jan-2022 1:08 PM
Collected by: Kelly Kish	Reported: 25-Jan-2022 2:15 PM
Station #: SK05NE0001	Water Source: Distributed
Permit: 2277 KIPLING DIST.SYSTEM	

Submitted By: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	Invoice: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	23.00
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-2515	Emailed results to: kiptown@sasktel.net kellykish@swwa.ca
---	---

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-787-6517
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .80	Total Chlorine: .80	Turbidity: .09
--------------------	---------------------	----------------