

Environmental Services Analysis Report - Final

Invoice Number: 3407239	Collected Date: 16-May-2022 7:45 AM	
Sample Location: Town Shop	Received: 17-May-2022 3:34 PM	
Collected by: Kelly Kish	Reported: 18-May-2022 2:26 PM	
Station #: SK05NE0001	Water Source: Distributed	
	Permit: 2277	Permit: 2277
	KIPLING DIST.SYSTEM	KIPLING DIST.SYSTEM

Submitted By:	Invoice:
Kipling Town of Box 299 Kipling, SK S0G 2S0	Kipling Town of Box 299 Kipling, SK S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-2515	Emailed results to: kiptown@sasktel.net kellykish@swwa.ca
---	---

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .58	Total Chlorine: .59	Turbidity: .13
--------------------	---------------------	----------------