

Environmental Services Analysis Report - Final

Invoice Number: 3501889	Collected Date: 21-Apr-2025 12:15 PM	
Sample Location: Town Shop	Received: 22-Apr-2025 3:52 PM	
Collected by: Kelly Kish	Reported: 23-Apr-2025 2:37 PM	
Station #: SK05NE0001	Water Source: Distributed	
Permit: 2277		
KIPLING DIST.SYSTEM		

Submitted By:

KIPLING TOWN OF
BOX 299
KIPLING, SK
S0G 2S0

Invoice:

KIPLING TOWN OF
BOX 299
KIPLING, SK
S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	23.00
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-8805

Emailed results to: b.ackerman@townofkipling.ca
kellykish1964@gmail.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Accounts Receivable
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 1-866-727-5420

Billing Inquiries: Phone: 1-833-989-5353, Email: SHAAR@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.71	Total Chlorine: 0.74	Turbidity: 0.12
---------------------	----------------------	-----------------