

## Environmental Services Analysis Report - Final

<b>Invoice Number:</b> 3374658	<b>Collected Date:</b> 15-Mar-2021 7:15 AM
<b>Sample Location:</b> Water Plant	<b>Received:</b> 15-Mar-2021 12:45 PM
<b>Collected by:</b> Kelly Kish	<b>Reported:</b> 16-Mar-2021 11:18 AM
<b>Station #:</b> SK05NE0001	<b>Water Source:</b> Distributed

**Permit: 2277  
KIPLING DIST.SYSTEM**

<b>Submitted By:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	<b>Invoice:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

<b>Submitter Phone Number:</b> 306-736-2515	<b>Emailed results to:</b> kiptown@sasktel.net glokel@sasktel.net
---	--

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

 Please include  
Invoice Number  
with payment  
and remit to:

**Saskatchewan Health Authority  
c/o Finance  
2180 23rd Avenue  
Regina, Saskatchewan  
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

<b>Balance Owed</b>	<b>\$23.00</b>
---------------------	----------------

**Contact Us:**

*Result Interpretation:* Please contact your EPO for advice or phone 306-787-6517  
*Billing Inquiries:* Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 1.05	Total Chlorine: 1.09	Turbidity: .10
---------------------	----------------------	----------------