

Environmental Services Analysis Report - Final

Invoice Number: 3388688 **Collected Date:** 07-Sep-2021 6:00 AM
Sample Location: WTP **Received:** 07-Sep-2021 12:07 PM
Collected by: Stacy H **Permit:** 2277 **Reported:** 08-Sep-2021 3:00 PM
Station #: SK05NE0001 KIPLING DIST.SYSTEM **Water Source:** Distributed

Submitted By: KIPLING TOWN OF
 BOX 299
 KIPLING, SK
 S0G 2S0

Invoice: KIPLING TOWN OF
 BOX 299
 KIPLING, SK
 S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-2515 **Emailed results to:** kiptown@sasktel.net
 kellykish@swwa.ca

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST)	23.00
Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-787-6517
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .80 Total Chlorine: .98 Turbidity: .19