



Saskatchewan Health Authority



Roy Romanow Provincial Laboratory
Environmental Services

5 Research Drive
Regina, Saskatchewan
S4S 0A4

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number: 3309724 **Collected Date:** 13-Nov-2018 7:14 AM
Sample Location: Water Plant **Received:** 13-Nov-2018 12:12 PM
Collected by: Kelly Kish **Permit:** 2277 **Reported:** 14-Nov-2018 11:15 AM
Station #: SK05NE0001 **Water Source:** Distributed

Submitted By: Kipling Town of Kipling, SK S0G 2S0
Invoice: Kipling Town of Kipling, SK S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-2515 **Emailed results to:** kiptown@sasktel.net, glokel@sasktel.net

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:
Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST) 23.00
Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)
Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed \$23.00

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-787-6517
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.48 Total Chlorine: 1.14 Turbidity: 0.21