

## Environmental Services Analysis Report - Final

<b>Invoice Number:</b> 3310701	<b>Collected Date:</b> 26-Nov-2018 7:15 AM
<b>Sample Location:</b> Water Plant	<b>Received:</b> 26-Nov-2018 1:42 PM
<b>Collected by:</b> Kelly Kish	<b>Reported:</b> 27-Nov-2018 2:16 PM
<b>Station #:</b> SK05NE0001	<b>Water Source:</b> Distributed

**Permit: 2277**  
KIPLING DIST.SYSTEM

<b>Submitted By:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	<b>Invoice:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

<b>Submitter Phone Number:</b> 306-736-2515	<b>Emailed results to:</b> kiptown@sasktel.net glokel@sasktel.net
---	--

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	<b>Saskatchewan Health Authority</b> <b>c/o Finance</b> <b>2180 23rd Avenue</b> <b>Regina, Saskatchewan</b> <b>S4S 0A5</b>	<b>Total Fees (including GST)</b> 23.00  <b>Tax Summary</b> 1.10 G.S.T. (reg # 89583 0180 RT001)  Amount Received: (No Payment Received) 0.00
<b>Balance Due upon receipt of invoice.</b>		<b>Balance Owed \$23.00</b>

**Contact Us:**

**Result Interpretation:** Please contact your EPO for advice or phone 306-787-6517  
**Billing Inquiries:** Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.36	Total Chlorine: 1.13	Turbidity: 0.16
---------------------	----------------------	-----------------