

## Environmental Services Analysis Report - Final

<b>Invoice Number:</b>	3385843	<b>Collected Date:</b>	03-Aug-2021 7:01 AM
<b>Sample Location:</b>	704 1st Street O/T	<b>Received:</b>	03-Aug-2021 3:39 PM
<b>Collected by:</b>	Kelly Kish	<b>Reported:</b>	04-Aug-2021 2:08 PM
<b>Station #:</b>	SK05NE0001	<b>Water Source:</b>	Distributed
	<b>Permit: 2277</b>		
	KIPLING DIST.SYSTEM		

<b>Submitted By:</b>	<b>Invoice:</b>
KIPLING TOWN OF	KIPLING TOWN OF
BOX 299	BOX 299
KIPLING, SK	KIPLING, SK
S0G 2S0	S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

<b>Submitter Phone Number:</b>	306-736-2515	<b>Emailed results to:</b>	kiptown@sasktel.net kellykish@swwa.ca
--------------------------------	--------------	----------------------------	--

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	<b>Saskatchewan Health Authority</b> <b>c/o Finance</b> <b>2180 23rd Avenue</b> <b>Regina, Saskatchewan</b> <b>S4S 0A5</b>	<b>Total Fees (including GST)</b>	23.00
		<b>Tax Summary</b> G.S.T. (reg # 89583 0180 RT001)	1.10
		Amount Received: (No Payment Received)	0.00
Balance Due upon receipt of invoice.		<b>Balance Owed</b>	<b>\$23.00</b>

**Contact Us:**

**Result Interpretation:** Please contact your EPO for advice or phone 306-787-6517  
**Billing Inquiries:** Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	0.90	Total Chlorine:	0.96	Turbidity:	0.14
----------------	------	-----------------	------	------------	------